Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AG7877

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

JL-DS60 Din Sashlock
JL-DL60 Latch & JL-DB60 Bathroom Lock
See Annex A

Intended use: For use on fire/smoke compartmentation doors

Essential characteristics	Performance	Designated standard
Mechanical test evidence: WIL 363447, WIL 368107 & WIL 368107-2 Fire test evidence: WF 358389 & WF 358393 Iss 2		
Self-closing ability 5.4.2 Closing force 5.1.2 Return force of latch bolt	 Grade 8: 200Kg door mass with 15N maximum closing force. >2.5N	EN 12209:2003 / AC:2005
Durability of self-closing action 5.3.1 Durability of latch action	Grade X: 200,000 cycles with 120N side load on latch bolt.	
Ability to maintain the door in the closed position and not contribute to its spread of fire 5.2.1 Resistance to side load on latch bolt 5.5 Suitability for use on fire/smoke doors	 Grade 3: 3kN Grade 1: suitable for use on fire/smoke resistant door assemblies	
Control of dangerous substances 5.1.1 Dangerous substances	Pass: The materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

This certificate is the property of Warringtonfire Testing and Certification Limited. Registered in England and Wales
Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AG7877

Placed on the market under the name of:

Frelan Hardware
Unit 10 Mitcham Industrial Estate
Streatham Road
Mitcham, Surrey
CR4 2AP
United Kingdom

and produced in the manufacturing plant

CUC89710-3

This is coded format, and the information is held by the Approved Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard:

EN 12209:2003 / AC:2005

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the Construction Product.

This certificate was first issued on **31/07/2021** and re-issued on **19/08/2024** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **29/07/2027**

Paul Duggan
Certification Manager

0087

Warringtonfire Testing and Certification Limited
Suite 302, The Genesis Centre, Birchwood, Warrington, WA3 7BH, UK

This certificate is the property of Warringtonfire Testing and Certification Limited. Registered in England and Wales
Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

Certificate of Constancy of Performance

1121-CPR-UK-AG7877

Annex A

Model No.	Description	Backset	Centres
JL-DS60	Upright Mortice Sashlock Square & Radiused forend	60mm	72mm
JL-DL60	Upright Mortice Latch Square & Radiused forend	60mm	N/A
JL-DB60	Upright Mortice Bathroom Lock Square & Radiused forend	60mm	72mm

Forends available in the following finishes:

SSS
PVD
MB
PVD SB
Electro
Plated AB

This certificate is the property of Warringtonfire Testing and Certification Limited. Registered in England and Wales
Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436