Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG5172

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

JEDO Range of Heavy-Duty Tubular Latches
See Annex A

Intended use: For use on fire/smoke compartmentation doors

Essential characteristics	Performance	Harmonised technical specification
Mechanical test evidence: WIL 397874, WIL 357084 & WIL 411036 Fire test evidence: WF 358393, WF 358389 & WF 375208 iss.4		
Self-closing ability 5.4.2 Closing force 5.1.2 Return force of latch bolt	Grade 7: 100Kg door mass with 15N maximum closing force. >2.5N	**EN 12209:2003 / AC:2005**
Durability of self-closing action 5.3.1 Durability of latch action	Grade C: 200,000 cycles with no side load on latch bolt.	
Ability to maintain the door in the closed position and not contribute to its spread of fire 5.2.1 Resistance to side load on latch bolt 5.5 Suitability for use on fire/smoke doors	Grade 1: 2kN Grade 1: suitable for use on fire/smoke resistant door assemblies	
Control of dangerous substances 5.1.1 Dangerous substances	Pass: The materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG5172

Placed on the Market under the Name of

Frelan Hardware Ltd
Unit 10 Mitcham Industrial Estate
Streatham Road
Mitcham
Surrey
CR4 2AP
United Kingdom

and produced in the manufacturing plant:

CUC89710-6

This is coded format, and the information is held by the Notified Body.

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

EN 12209:2003 / AC:2005

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **21/10/2020** and re-issued on **09/10/2024** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

Valid to: **05/09/2027**

ERO Project Reference: **ERO 034621 P2336**

Pascal Coget
General Manager – European Certification

CSF408-NL 8.0

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG5172

Annex A

Model No.	Description	Backset
JL-HDT102	102mm Heavy duty tubular latch Square forend	80mm
JL-HDT76	76mm Heavy duty tubular latch Square forend	57mm
JL-HDT64	64mm Heavy duty tubular latch Square forend	44mm

Forends available in the following finishes:

SSS	**Satin stainless steel**	**PVD**	**Polished brass**
PSS	**Polished stainless steel**	**AB**	**Antique brass**
MB	**Matt black**	**SB**	**Satin brass**
GM	**Gun metal**	**DB**	**Dark bronze**