

Notified Body No. 2812

Certificate of Constancy of Performance 2812-CPR-AC5109

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

J9400 Series Grade 14 Concealed Bearing Butt Hinge See Annex A

Intended use: For use on fire/smoke compartmentation doors, and escape route doors

Essential characteristics	Performance	Harmonised technical specification
Mechanical test evidence: WIL 418376 & WIL 423616 Fire test evidence: WF 419361		
Self-closing Initial friction torque (door mass 160kg) Static load Load deformation	< 4Nm Passed with a displacement under load: - lateral < 2mm - vertical < 4mm and a residual displacement after unloading: - lateral < 0.6mm - vertical < 0.3mm - within the shaded area of figure G.1	EN 1935:2002 / AC:2003
Overload	Passed	
Shear strength	Passed with a lateral and vertical displacement after unloading < 3mm	
Hinges for use on fire-resistant and/or smoke-controls doors	Grade 1: suitable for use on fire/smoke resistant door assemblies	
Durability	Passed a 200,000 cycle test with a maximum wear: - lateral < 0.5mm - vertical < 1mm and with a maximum frictional torque. - after 20 cycles < 4Nm - after the completion of 200,000 cycles < 4Nm	
Families of hinges with common design features	The hinge covered by this certificate is the hinge tested	
Corrosion resistance	Grade 4: 240 hours	
Dangerous substances	Pass: the materials in the hinge do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AC5109

Placed on the market under the name of:

**Frelan Hardware Ltd
Unit 10 Mitcham Industrial Estate
Streatham Road
Mitcham
Surrey
CR4 2AP
United Kingdom**

and produced in the manufacturing plant

J/089

This is coded format and the information is held by the Notified Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard:

EN 1935:2002 / AC:2003

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **21/10/2020** and re-issued on **18/07/2023** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **17/07/2026**

ERO Project Reference: **ERO 034621 P1941**



Pascal Coget

General Manager -
European Certification

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AC5019

Annex A

Model Reference	Description
J9400SSS	102 x 76 x 3mm SS201 stainless steel concealed bearing hinge Satin stainless steel finish Square corners
J9400BL	102 x 76 x 3mm SS201 stainless steel concealed bearing hinge Matt black finish Square corners
J9400DB	102 x 76 x 3mm SS201 stainless steel concealed bearing hinge Dark bronze finish Square corners
J9400SB	102 x 76 x 3mm SS201 stainless steel concealed bearing hinge Antique brass finish Square corners

CSF408-NL 7.0