Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG5234

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

JEDO Range of Architectural 3 Lever Mortice Sashlocks / Architectural 3 Lever Bathroom locks / Euro-profile Cylinder Sashlock & Oval-profile Cylinder Sashlock

Intended use: For use on fire/smoke compartmentation doors

Essential characteristics	Performance	Harmonised technical specification
Mechanical test evidence: WIL 503007 / WIL 503008 / WIL 503008-1 / WIL 522681 / WIL 537739 / WIL 537740 & WIL 548047 Fire test evidence: WF 419361 Iss 2 / WF 421087 iss.6 & WF 429674		
Self-closing ability 5.4.2 Closing force 5.1.2 Return force of latch bolt	Grade 8: 200Kg door mass with 15N maximum closing force. >2.5N	**EN 12209:2003 / AC:2005**
Durability of self-closing action 5.3.1 Durability of latch action	Grade M: 200,000 cycles with 25N side load on latch bolt.	
Ability to maintain the door in the closed position and not contribute to its spread of fire 5.2.1 Resistance to side load on latch bolt 5.5 Suitability for use on fire/smoke doors	Grade 2: 3kN Grade 1: suitable for use on fire/smoke resistant door assemblies	
Control of dangerous substances 5.1.1 Dangerous substances	Pass: The materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG5234

Placed on the Market under the Name of:

Frelan Hardware Ltd
Unit 10 Mitcham Industrial Estate
Streatham Road
Mitcham
Surrey
CR4 2AP
United Kingdom

and produced in the manufacturing plant:

CUC89710-3

This is coded format, and the information is held by the Notified Body.

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

EN 12209:2003 / AC:2005

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **21/07/2021** and reissued on **19/05/2025** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

Valid to: **20/07/2027**

ERO Project Reference: **ERO 034621 P2341**

Pascal Coget
General Manager – European Certification

CSF408-NL 8.0

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG5234

Annex A

Model No.	Description	Backset	Centres
JL1071	Architectural 3 – Lever bathroom lock	44mm	57mm
JL1072	Architectural 3 – Lever bathroom lock	57mm	57mm
JL1090	Architectural 3 – Lever sashlock	44mm	57mm
JL1091	Architectural 3 – Lever sashlock	57mm	57mm
JL1050	Euro-Profile Cylinder Sashlock	44mm	57mm
JL1051	Euro-Profile Cylinder Sashlock	57mm	57mm
JL1052	Oval-Profile Cylinder Sashlock	44mm	57mm
JL1053	Oval-Profile Cylinder Sashlock	57mm	57mm
Available in square and radius Forends			

Forends available in the following finishes:

PB Polished Brass
PC Polished Chrome
SC Satin Chrome
MB Matt Black
SB Satin Brass
AB Antique Brass
DB Dark Bronze